



## APPROVED PRIORITY LIST PY's 2013 – 2015

### SOUTHWEST GAS LOW-INCOME ENERGY CONSERVATION PROGRAM APPROVED PRIORITY LIST PY's 2013 - 2015

All of the measures below are to be installed in accordance with the Nevada Housing Division Weatherization Field Manual. The measures should be installed in the sequence listed, unless otherwise directed.

1. **Health and Safety Activities (Shall not exceed 15% of total budget for each subgrantee.):**
  - a. Allow CAS and Blower Door Testing with SWG funds when *no other funds are used* in conjunction.
  - b. Primary Heating System –Repair or Replace with a natural gas 90% AFUE unit if the unit is inoperable or unsafe based on the HVAC evaluation.
  - c. Repair/Replace Gas Water Heater (CAS Failure only)
  - d. Repair/Replace Gas Cooking Appliances. (CAS Failure only)
  - e. Replace damper and/or exhaust fan when inoperable (Mobile Homes with gas appliances only)
  - f. CO Alarms (Maximum 2 per dwelling)
  - g. Repair or replacement of leaking hot water controlling valves in kitchen or bath.
2. Duct Sealing
3. Shell Sealing to ESP

**In addition to the above, install the following measures based on housing type:**

#### **Single Family:**

4. Floor Insulation (where none exists)
5. Duct Insulation (where none exists)
6. Attic Insulation (supersedes floor insulation if none existing) Bring attic up to R-38 if existing is R-19 or less, must include attic hatch insulation. If existing is above R-19 but hatch is not insulated, insulate hatch only with R-19.
7. Low flow showerhead
8. Water Heater Blanket (unconditioned space)
9. Water Heater Pipe Wrap (unconditioned space)
10. Complete replacement of deteriorated/worn out duct system (with natural gas heat source only).
11. Replacement of heating system thermostats or relocation if HVAC is being replaced.
12. Dual Pane Windows may only be installed if replacing jalousie or broken windows
  - a. Operable single pane windows with storms do not qualify. Photo is required.
  - b. For homes built pre-1978, all lead safe work practices apply or installation of measure is non-feasible



## APPROVED PRIORITY LIST PY's 2013 – 2015

### **Mobile Home:**

4. Floor Insulation (where none exists)
5. Low flow showerhead
6. Water Heater Blanket (unconditioned space)
7. Water Heater Pipe Wrap (unconditioned space)
8. Dual Pane Windows (only in place of jalousie or broken windows; operable single pane windows with storms do not qualify. Photo required)

### **Multi- Family:**

The only allowable measures for Multi-family Dwellings (1-4 units located in multi-building complex under single ownership and 5+ unit buildings under single ownership) are as follows:

- Water heater blanket (unconditioned space)
- Water heater pipe wrap (unconditioned space)
- Low flow showerhead
- Duct Insulation – R-8 or higher (where none exists)
- Floor Insulation (where none exists)
- Ceiling Insulation – Bring attic up to R-38 if existing is R-19 or less, must include attic hatch insulation. If existing is above R-19 but hatch is not insulated, insulate hatch only with R-19.